UNDERGROUND STORAGE TANK SYSTEM
LEAK ALARM LOG

Per California Health and Safety Code, Chapter 6.7, §25293, the operator of an underground storage tank (UST) system must keep monitoring records in sufficient detail to enable the local Unified Program Agency to determine whether the UST system is being operated in compliance with applicable UST regulations. All leak alarms from the UST monitoring system must be logged. **(Do not log non-leak alarms such as Delivery Needed.)**

Facility Name: _____

Date	Time	Alarm	Cause	Recorded By	Comments/Corrective Actions
(EXAMPLE) 8/1/2014	12:30pm	L7 – DISPENSER 1/2	Gas spill into pan from filter change.	Jan Smith	8/1/2014 - Cleaned up spill. Placed absorbent pad in waste drum. Alarm cleared.

This log is part of the facility's underground storage tank monitoring records and must be kept on-site for a minimum of three (3) years.